



PRIORITY DEFENSIBLE SPACE REQUIREMENTS

REDUCED TO 5 SIMPLE STEPS

Weeds & Grasses:

Remove all weeds and grasses within 5 feet of structure and cut below 4 inches in all other areas (within 100 feet or to the property line).

Pine Needles:

Remove all pine needles and other forest litter from roofs, decks, & within 5 feet of the structure. Also reduce to 2 inches in all other areas (within 100 feet or to the property line).

Tree Limbs:

Prune all tree limbs back 10 feet from chimney and roof line, prune bottom limbs up off of ground and remove all dead limbs.

High Energy Release Vegetation (Juniper, Manzanita, etc.):

Remove from within 15 feet of structure or 10 feet of roadway, driveways, fencing, hydrants and propane tanks. In all other areas High Energy Release vegetation should be spaced apart by doubling the height of the tallest shrub. (Example: If you have a 6 ft. shrub high energy release vegetation should be spaced out 12 ft.)

Firewood:

Up to 1 cord may be against the structure if covered with fire-resistant tarp. All other firewood must be neatly stacked away from structure in a manner that does not increase fire risk.